



INDIANA STATE FIRE MARSHAL

NOTICE OF VIOLATIONS AND ORDER TO CORRECT - CLASS 1 STRUCTURES

| | | | |
|----------------|---------|-----------------|--------|
| Facility Name | Address | City | Zip |
| Inspector Name | | Inspection Date | ID No. |

| | Code Requirement | Met | Not Met | N/A |
|----|--|-----|---------|-----|
| | FIREWORKS SOLD IN CLASS I STRUCTURES. | | | |
| 1. | <u>Sec. 107.2.1 I.F.C. 2003 Edn.</u> Written records of maintenance, test and inspections shall be maintained on the premises where the equipment is located, or at a central corporate office, and shall be made immediately available to the inspection authority on request. PROVIDE DOCUMENTATION FOR REVIEW BY THIS OFFICE SHOWING THAT THE BI-ANNUAL SMOKE DETECTOR SENSITIVITY TEST HAS BEEN COMPLETED AND THAT NO NON-COMPLIANCES HAVE BEEN NOTED. | | | |
| 2. | <u>Sec. 107.2.1 I.F.C. 2003 Edn.</u> Written records of maintenance, test and inspections shall be maintained on the premises where the equipment is located, or at a central corporate office, and shall be made immediately available to the inspection authority on request. PROVIDE DOCUMENTATION FOR REVIEW BY THIS OFFICE SHOWING THAT THE ANNUAL FIRE ALARM TEST HAS BEEN COMPLETED AND THAT NO NON-COMPLIANCES HAVE BEEN NOTED. | | | |
| 3. | <u>Sec. 107.2.1 I.F.C. 2003 Edn.</u> Written records of maintenance, test and inspections shall be maintained on the premises where the equipment is located, or at a central corporate office, and shall be made immediately available to the inspection authority on request. PROVIDE DOCUMENTATION FOR REVIEW BY THIS OFFICE SHOWING THAT AN ANNUAL COMPLETE SPRINKLER SYSTEM TEST HAS BEEN PERFORMED AND THAT NO NON-COMPLIANCES HAVE BEEN NOTED. | | | |
| 4. | <u>Sec. 605 I.F.C. 2003 Edn.</u> Electrical equipment and installations shall comply with Sec. 605. | | | |
| 5. | <u>Sec. 906.1 I.F.C. 2003 Edn.</u> Portable fire extinguishers shall be installed where required by Table 906.1 and where required by local ordinance. | | | |
| 6. | <u>Sec. 1003.2.8 I.F.C. 2003 Edn.</u> Obstructions, including storage, shall not be placed in the required width of a means of egress, except projections as allowed by the Building Code. The required capacity of a means of egress system shall not be diminished along the path of egress travel. | | | |
| 7. | <u>675 IAC 12-4-9(a)</u> – The building shall be maintained in accordance with the Indiana Building Code in effect at the time the occupancy classification use began. | | | |
| 8. | <u>Sec. 1003.2.11.2 IFC</u> – Exit emergency lighting shall be maintained in operable condition | | | |



INDIANA STATE FIRE MARSHAL

| | | | | |
|-----|--|--|--|--|
| 9. | <u>Sec. 703.2 IFC</u> – Fire rated construction and opening protection shall be maintained in accordance with Section 703.2 | | | |
| 10. | <u>Sec. 1011.2 IFC</u> – Exit doors shall be maintained free from obstructions or impediments to full instant use in the case of fire or other emergency. | | | |
| 11. | <u>Sec. 1011.3 IFC</u> – Furnishings, decorations or other objects shall not be placed so as to obstruct exits, access to exits or visibility of exits. | | | |
| 12. | <u>Sec. 1003.2.11 IFC</u> – Exit signs shall be illuminated and operational at all times that the structure is occupied. | | | |
| 13. | <u>Sec. 310 IFC</u> – No smoking signs shall be posted in each location in which fireworks are sold, offered for sale or stored. | | | |
| 14. | <u>Sec. 308 IFC</u> – No open flame devices shall be used in any location in which fireworks are sold, offered for sale or stored. | | | |
| 15. | <u>Sec. 315 IFC</u> – Combustible storage shall comply with the provisions of Section 315. | | | |

NOTES:

Please be advised that if you desire administrative review of this Order, you must file a written petition for review with the Fire Prevention and Building Safety Commission at 402 West Washington Street, Rm. W246, Indianapolis, IN 46204, identifying the violations for which you seek review no later than 18 days from the date of this Order unless such date is a Saturday, Sunday, legal holiday under state statute, or day that the Department of Homeland Security's offices are closed during regular business hours, in which case the deadline would be the first day thereafter that is not a Saturday, Sunday, legal holiday under state statute, or day that the Department of Homeland Security's offices are closed during regular business hours. If you do so, your petition for review will be granted and an administrative proceeding will be conducted by an administrative law judge appointed by the Fire Prevention and Building Safety Commission. If you do not file a petition for review, this Order will be **FINAL** and you **MUST** comply with its requirements.

Please be further advised that you may request an opportunity to informally discuss this Order prior to filing a petition for review. Such informal discussion, or a request therefore, does not extend the deadline for filing a petition for review and, therefore, any request for an informal discussion should be made promptly, preferably by telephone, upon receipt of this Order.

Authorized Fire Official's Signature

Date